



Snow Load

Roof snow load criteria for Ouray County are determined by building site elevation, as follows:

<u>Elevation</u>	<u>Snow Load</u>
Under 6,500 ft.	30 psf
6,550-7,000 ft.	38 psf
7,000-7,500 ft.	47 psf
7,500-8,000 ft.	58 psf
8,000-8,500 ft.	68 psf
8,500-9,000 ft.	80 psf
9,000-9,500 ft.	92 psf
9,500-10,000 ft.	106 psf
10,000-10,500 ft.	121 psf
10,500-11,000 ft.	135 psf
11,000-11,500 ft.	152 psf

Wind Load

The minimum basic wind speed for determining design wind pressure at any site shall not be less than 70 miles per hour.

Frost Depth

The mean frost depth in Ouray County has been established at forty (40) inches. Frost depth will be measured from the top of the footer to finished grade.